

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7125-1483:163

Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models MG1-CVM, MG1-CVM. MG1R-CVM, MG1RF-CVM, *MG1-CV1575, *MG1R-CV1571, *MG1F-CV1575, and *MG1RF-CV1575 electronic chime/strobes. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Electrical: 16-33 Vdc, Vfwr
Candela: 15cd, 30cd, 75cd, 110cd selectable MG1-CVM Series
15/75 MG1-CV1575 Series

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as electronic chime/strobe for use with separately listed compatible fire alarm control units. For indoor use and wall mount only. Also suitable for audible devices. Refer to listee's Installation Instruction Manual for details.

These units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal(for total evacuation) in accordance with NFPA 72, 2002 Edition.

XL: 7125-1591:220

*Rev. 01-19-2006 jew



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division